
INSTRUCTION SHEET

725 SERIES I/O MODULE REPLACEMENT

Two nylon mounting spacers are supplied with this hardware kit. If the existing assembly has aluminum mounting spacers, the nylon spacers should be used when installing a new I/O module.

If the hardware kit is needed to reinstall an existing I/O module it is recommended to use the nylon spacers even when a new I/O module is not being used.

